

- 1. TANK IS MANUFACTURED FROM POLYETHYLENE (PE) OR CROSSLINK PE (XLPE).
 2. RATING FOR STORING LIQUIDS WITH A SPECIFIC GRAVITY (DENSITY) OF 1.5SG.
- (1.9SG ALSO AVAILABLE)


 3. ALL TANK DIMENSIONS ARE SUBJECT TO A +/-3% TOLERENCE.

 4. ALL EXTERNAL PIPING AND ACCESSORIES MUST BE FULLY SUPPORTED AND
- FLEXIBLE TO AVOID STRESSING THE TANK.

 5. FITTING GASKETS AVAILABLE IN EPDM OR VITON.

 6. TANK MUST BE PROPERLY VENTED TO PREVENT PRESSURE OR VACUUM FROM DEVELOPING AS THE TANK IS FILLING OR EMPTYING.
- 7. STANDARD LID IS 15" NON-VENTED. LID ALSO AVAILABLE IN 21" VENTED OR NON-VENTED.
- 8. TANK IS MANUFACTURED TO ASTM-D-1998 STANDARD

| MATERIALS LIST | | | | | | |
|----------------|-------------------------|-------|--|--|--|--|
| ITEMS | DESCRIPTION | NOTES | | | | |
| Α | CT-7340 CLOSED TOP TANK | | | | | |
| В | 15" THREADED LID | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |



| | REV | DATE | I | BY | APPD | REV | | | | |
|----------|----------------------|-------------------------|--------------------|------------------------|------|-----|--|--|--|--|
| | | | | REVISIONS | | | | | | |
| CUSTOMER | | | | | | | | | | |
| | | | | | | | | | | |
| TITLE | | | | ACO JOB NO: | | | | | | |
| 7300 |) IG CLOSED TOP TANK | | PURCHASE ORDER NO: | | | | | | | |
| | . 300 | 70 10 CEOSED 101 17 WW. | | PURCHASER'S EQUIP. NO: | | | | | | |
| | | | | | | | | | | |

THIS DRAWING IS THE PROPERTY OF ROTOPLAST INC.
AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE
WRITTEN CONSENT OF ROTOPLAST INC.

ENGINEERS SEAL

ACO CONTAINER SYSTEMS DIVISION OF ROTOPLAST INC.


N.T.S. 02-03-16

REV 0

DESIGNED DRAWN ACO CONTAINER SYSTEMS
DIVISON OF ROTOPLAST INC.
794 MCKAY RD.
PICKERING, ONTARIO, CANADA CHECKED

APPROVED SCALE DATE TEL. 905-683-8222 FAX 905-683-2969

CT-7340





| A |) |
|-----------------|---|
| 142"—FRONT VIEW | |